

From: Dave Ogborne [<mailto:Dave.Ogborne@wessexwater.co.uk>]

Sent: 10 January 2018 08:17

To: pimperne@dorset-aptc.gov.uk

Subject: WWResp - DLP/29112017 Pimperne Neighbourhood Plan

Dear Kath

Apologies for the delayed response from Wessex Water. I have set out a number of comments below

Pimperne N Plan

We note the housing requirements of 40 – 45 new dwellings and locations considered in the plan. None of the sites appear to affect existing apparatus.

There is capacity available from local networks to provide water supply and waste water services for the planned growth.

Foul sewers drain to Tarrant Crawford STW where capacity is available for treatment.

There are no recorded public surface water systems in this location. Please note that no surface water connections will be permitted to the foul sewer. It is paramount that sites are promoted with a satisfactory means of disposal for surface water to infiltration or local land drainage systems.

If any further information is required please advise.

regards

Dave Ogborne

Planning Liaison Manager

Wessex Water

Claverton Down

Bath

BA2 7WW

DD 01225 526169

dave.ogborne@wessexwater.co.uk